

Certificate of Compliance



This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

You have been awarded:

Intertek ETL US Mark for Building Panels

Standards: ASTM E84 (2021)

Certificate number: WHI22-33043407

Organization: Ask Gypsum Factory Ltd

Light Industrial Area, Al Sinaiyah

Yanbu 51000

Kingdom of Saudi Arabia

Product: ASK Gypsum Factory - Gypsum boards (Gboard)

Spec ID: 66153

Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.

Initial registration: January 25, 2022

Date of expiry: December 31, 2024

Issue status: 3

Authorized By:

Jean-Philippe Kayl, Director of Certification

A handwritten signature in black ink, appearing to read 'Jean-Philippe Kayl', is written over a horizontal line.

Intertek Testing Services NA, Inc.

545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA

Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

The following ASK Gypsum Factory Gypsum boards are Certified by Intertek:

Gboard Core– This gypsum board consists of a gypsum plaster core with a paper bonded to each face. The face paper is green in colour. Gboard Core is available only in 25mm thickness.

Gboard Advanced FR – This gypsum board consists of a gypsum plaster core with a paper bonded to each face. The face paper is pink in colour. Gboard Advanced FR boards are available in 12.5mm and 15mm thicknesses.

Gboard Advanced MFR – This gypsum board consists of a gypsum plaster core with a paper bonded to each face. The face paper is green in colour. Gboard Advanced MFR boards are available only in 12.5mm thickness.

FLAME SPREAD RATINGS

Test Standard	Flame Spread	Smoke Development
ASTM E84	25 or less	450 or less